



## **ADDENDUM No. "2" to RFP No. B2014022**

### **Fire Alarm, Sprinkler, and Clean Agent Systems Testing, Inspection, Maintenance & Repair – RITT**

Date of Addendum No. "2" Issued: January 21, 2015

Purpose of this Addendum is to:

- Provide answers to questions received via email to the Purchasing Office

1. Page 6 – States "All parts delivered and installed within 24hours of service call". Does this apply if parts are not immediately available and need to be ordered?

Due to the nature of life safety system requirements, vendor is responsible for obtaining necessary parts including overnight delivery if needed.

2. Page 6 – States "Work after regular business hours will be deemed Over Time that is not part of a routine repair." Can you specify a routine repair?

Vendor may troubleshoot and make assessments for repair issues during normal business hours. Any repairs that involves sounding horns or may be distracting to court or office work needs to be schedule outside court hours.

3. #26 in the RI Judiciary Terms – talks about prevailing wage. Is this testing Prevailing Wage?

Yes, it is a prevailing wage job.

The General Terms and Conditions of Purchase is standard language contained in every rfp issued by the Judiciary.

4. Can you please clarify if there is a dry system or anti-freeze system at this location?

No Dry System or Antifreeze; this area is heated.